



P. O. Box 1147, Robstown, Texas 78380  
(361) 387-4549

---

## **SURFACE WATER MONITORING, ROUTINE MAJOR**

The **NUECES COUNTY WCID 3** water system, **PWS ID TX1780005**, has violated the monitoring/reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Public water systems that treat surface water and/or ground water under the direct influence of surface water are required to submit monthly operating reports with operational data of the water provided to their customers.

We failed to monitor and/or report the performance of direct integrity test (DIT) of filter membranes with the required 7-day time frame.

This/These violation(s) occurred in the monitoring period(s): **September, 2018; 9/01/2018 – 9/30/2018**

Results of regular monitoring are an indicator of whether or not your drinking water is safe. We did not complete all monitoring and/or reporting for surface water treatment, and therefore TCEQ cannot be sure of the safety of your drinking water during that time.

We are taking the following actions to address this issue:

**Operators were counseled on importance of performing their duties in a timely manner with no excuses. Next deficiency will incur a written reprimand.**

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact John D. Herrera, District Manager at (361) 387-4549.

Posted/Delivered on: November 16, 2018